

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-12-11-26-07

Product: Hakwood Authentic Collection
 European Oak
 Variant 1: Duoplank, thickness: 20 mm
 Variant 2: Duoplank light, thickness: 15 mm

Producer: Hakwood, Leemansstraat 2, 4251 LD WERKENDAM, The Netherlands

Order/ Test method: Testing of selected properties for CE-labelling according to EN 14342

Test report: 272128, SP report PX11213-5, SP report PX11213-1

Test results: The tested variant wood flooring can be classified regarding to several properties according to EN 14342:2005 + A1:2008 (CE-labelling) as follows:

Variant	Property	Result	Declaration according to EN 14342
1	Fire classification	C _{fl} -s1	C _{fl} -s1
2	according to EN 13501-1	C _{fl} -s1	C _{fl} -s1
1	Formaldehyde emission	0,01 ppm	class E1
2	according to EN 717-1	Not detectable	class E1
1	PCP-content	Not detectable	Not to declare
2	according to CEN-TR 14823	Not detectable	Not to declare
1	Anti-skid properties	USRV 59	USRV 59
2	according to CEN/TS 15676	USRV 59	USRV 59
1	Maximum load		
	according to EN 1533		
	Span: 400 mm	6280 N	6280 N
	Span: 600 mm	5470 N	5470 N

Dresden, November 28th 2012

R. Ammer

Head of laboratory



G. Jäger

Engineer in charge