

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-12-11-26-09

Product: Variant 1: Hakwood Duoplank, thickness t: 15 ≤ t ≤ 20 mm
 Variant 2: Hakwood Duoplank light, thickness t: 10 ≤ t < 15 mm

Producer: Hakwood
 Leemansstraat 2
 4251 LD WERKENDAM
 The Netherlands

Order/ Test method: Determination of the Formaldehyde emission according to EN 717-1

Test report: 272128, SP report PX11213-5, SP report PX11213-1

Test results: *The above mentioned parquets can be classified regarding to several property according to EN 14342 as follows:*

Variant	Property	Result	Declaration according to EN 14342
1	Formaldehyde emission according to EN 717-1	0,01 ppm	class E1
2		not detectable	class E1

Dresden, November 28th 2012

R. Ammerla

Head of laboratory



[Signature]

Engineer in charge